

ASSAM POWER GENERATION CORPORATION LTD.

Corrigendum of E-Tender Notice

**Corrigendum of E-Tender No. APGCL/CGM (G)/NTPS (R&M)/Multi Fire
Tender/2018-19/1 dtd.17/11/2018**

**Name of work: Procurement of Multi Purpose Fire Tender at Namrup
Thermal Power Station (NTPS), APGCL, NAMRUP.**

Rectification of BOQ specification occurred due to typing error is as follows:

1.02 Fabrication cost of Multipurpose fire tender on 16 Ton chassis along with Multi-pressure Pump- 2000 lpm@7bar & 300 lpm@ 30 bar. Water Tank- 4500 liter made by S.S 316, 5mm sheet, and Foam tank 500 ltr made by S.S 304 with suitable gear ratio.

P.T.O, 32x32x2 mm M.S sqr tube structure. Manual exhaust Primer along with automatic primer.

DCP: 1x75 KG, CO2: 2x22.5 KG

Accessories as per relevant IS code.

1.03 Water mist system with 38 lpm pump @ 100 bar, safety valve, unloader valve and high pressure gun.

For details of above Tender notice visit our web site www.apgcl.org & <https://assamtenders.gov.in>

Sd/-

Chief General Manager (Gen), APGCL